

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 548

Dated: 26/09/2025

It is certified that an inspection team headed by Surender Kumar (AE)

(Name of Officers with designation) from Rohtak PHED

inspected the New Vidya Bharti Public School, Dhamra, RTK

(Name & Address of the school) on 25/09/2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. RTK/0247/9/2025 dated 26/09/2025

of PHED Water Testing Lab, Rohtak (PHED Lab) certified that

the New Vidya Bharti Public School, Dhamra (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 25/09/2026

Signature with Seal: [Signature] Assistant Engineer
Name: Public Health Engineering
Designation: Division, Rohtak
Name & Address of the Office / Department :

To New Vidya Bharti
Public School, Dhamra, Rohtak
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

PUBLIC HEALTH ENGINEERING DEPARTMENT

DISTRICT WATER TESTING LABORATORY, ROHTAK

Website: - <https://phedharyana.gov.in/>

Memo No:- 872

Date:- 26/09/2025

Subject : Physical / Chemical Examination Report of Water Sample

Sample ID/Classification : RTK/0247/9/2025 / Private	Sample Details	Date & Time
Sender : New Vidya Bharti Public School	Collected By	Virender Singh
Location : , VPO - Dhamar	Collection Date	25/09/2025 at 11:00
Sample Description : Drinking Water	Received at lab	25/09/2025 at 12:10
Latitude / Longitude : 76.666112 / 28.956717	Analysis Start Date	26/09/2025
	Analysis End Date	26/09/2025
	Sample Quantity	1Ltr

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Lmt. (In the Absence of Alternate Source)	Protocol Used
1	Total Dissolved Solids @ 180°C ± 2°C	429	500 mg/lit.	2000 mg/lit.	IS 3025 (Part-16) : 2023 /APHA 24th Edition-2540 C
2	Total Hardness as CaCO ₃	131.26	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2340 C
3	Calcium as Ca	27.42	75 mg/lit.	200 mg/lit.	APHA 24th Edition-3500-Ca B
4	Magnesium as Mg	87.77	30 mg/lit.	100 mg/lit.	APHA 24th Edition -3500 Mg B
5	Total Alkalinity	107.15	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2320 B
6	Chloride as Cl	70.18	250 mg/lit.	1000 mg/lit.	APHA 24th Edition -4500 Cl-B
7	Sulphate as So ₄	32	200 mg/lit.	400 mg/lit.	USEPA
8	Fluoride as F	0.08	1.0 mg/lit.	1.5 mg/lit.	USEPA
9	Iron as Fe	0.03	1.0 mg/lit.	1.0 mg/lit.	USEPA
10	Nitrate as No ₃	3.2	45 mg/lit.	45 mg/lit.	USEPA
11	pH @ 25°C	7.23	6.5 - 8.5	6.5 - 8.5	APHA 24th Edition 4500-H+ B
12	Free Residual Chlorine	0.0	0.2 mg/lit.	1.0 mg/lit.	

Remarks :-

- * The Results Given above are related to the sample as received and tested in PHED ROHTAK Lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.
- * The test samples meant for chemical analysis will be disposed off after 7 days from the data of issue of test report unless until specifically requested by the customer for retaining over a longer period.

Water Sample has been found "CONFORMING" to Limits set in BIS10500:2012 for the tested parameters.



Sample analyzed by :


SANDEEP ,CHEMIST
 DISTRICT WATER TESTING LABORATORY ROHTAK
 email:-chemist.rohtak@phedharyana.gov.in